






# (Selected Items on) Quality Control at Aachen





# Quality Control



-  QC of components (Al-plates, I-beams, HVB, HVC, FEB)
-  QC during mechanical production (wire tension, position, corner block position, 1.strip/I-beam)
-  QC after mechanical production / during assembly with HV & FE (Gastightness, HV test in air & gas, noise, efficiency, mean time)
-  Storage of QC data



# Positions of wire, 1.strip & corner blocks



## WIRE POSITION

### QC requirement:

-Tolerance: nominal position  $\pm 100 \mu\text{m}$ , measure FE & HV end

- Record in data base

### QC @ Aachen:

Measure every wire position before closing layer, exchange till all positions are within limit

System calibrated with LED-system and reference bar

Output: final file with only positions within limits

## POSITION OF 1.STRIP

### QC requirement:

-Tolerance is  $500 \mu\text{m}$ , nominal?

- Record in data base

- Correction?

### QC @ Aachen:

Measured 3-4 times along strip

### Output:

paper document [4]

## CORNER BLOCK POSITION

### QC requirement:

-Measure corner block w.r.t. closest wire before closing SL

- Record in data base

### QC @ Aachen:

Measured

### Output:

Paper document [4]

Non-straight strips ? More positions?

Recording without correction



# Wire Tension



## QC requirement:

measure individual wires  
before closing the layer,  
allowed range 230 – 325  
gr, no recording

## QC @ Aachen:


ALL wires are measured and  
stored in a local file

Frequency range phi 79.3 –  
83.3 Hz, theta 90 – 98 Hz

Wires with frequencies outside  
this range get replaced

## Output:

file with all wire tensions,  
only within tolerances  
(ASCII-> root)






# Planarity



Planarity of individual layers, SL007  
below 200 micron



**SL Planarity,**  
for first 14 SL  
measured for  
every layer.  
**Later just top  
layer + cover.**

**Output:**  
**Excel-file per SL**





## Planarity of Honeycomb-panels

- **Measured at Aachen: Hight over flat table (several points per HC) -> HR talk**
- **Output: local file**



# Quality Control



-  QC of components (Al-plates, I-beams, HVB, HVC, FEB)
-  QC during mechanical production (wire tension, position, corner block position, 1.strip/I-beam)
-  QC after mechanical production/ during assembly with HV & FE (Gastightness, HV test in air & gas, noise, efficiency, mean time)
-  Storage of QC data



# Gas Tightness (7.3 + 7.4)



QC requirement: 2 methods (pressure drop, oxygen content)

Record in DB

**Pressure drop measurement  
is more relevant!**

QC @ Aachen:

- **Pressure drop at 2 levels (2 HV-covers, FE+HV) for all SL**
- **→ excellent results**
- **Oxygen content just started recently**
- **Information to store: 1 time constant per SL with final settings,  
Web accessible**

**Gas tightness is essential for operation of CMS Muon system. We should make an effort to have good gas tightness. Time constants around 1000 are feasible.**



# Results from Pressure Drop



QC requirement:  $\tau > 135$  min

With two HV covers, time constant on average  $\tau \sim 1500$  min

In final conditions (FE+HV)  $\tau = 1200$  min

Pressure drop:

$$\tau = t / \ln \left( \frac{P_{i0} - P_a}{P_i - P_a} \right)$$

$P_i$  = pressure at  $t=0$


$P_a$  = pressure after  $t>0$

Our observations:

Recommended to first measure with two HV covers (check of FE-cover tightness during second measurement)

In case of leakage,  $\tau < 5$  min

If additional sealing required, usual close to corner-blocks







# HV Test in Air (7.2)



## Aachen Method:

1. Ramp-up strips (2.5 kV) and cathodes (-2 kV) without HVB for 10 min, granularity: 16
2. Connect HVB and ramp-up to  $V_{\text{wire/strip/cath}} = 3.9/1.9/1.6$  kV
3. Monitor currents with a resolution of 10 nA.

Require rest-currents  $\leq 200$  nA per HV channel

Time dependance observed (increase by  $\sim 10$  during days, then stable)

- Changes triggered by HV problems in gas:
- Increased HV-values in air, aiming at values for HV stability in gas:
- **Strips 1.8 kV (gas)  $\rightarrow$  3.3 (air)**
- **3.8 kV  $\rightarrow$  Cathodes 1.4 (gas)  $\rightarrow$  2.5 (air)**
- **3.1 kV**

**In QCD common current-limit. We observe  $I_{\text{wire/strip/cath}} \sim 10 / 50 / 75$  nA**

**In air mainly problems with strips.**

for several hours. Over night run starting with gas. Current fluctuations. with one SL. More statistics needed.




# Distribution of rest-currents for strips and cathodes



Rest currents after >10min in air ("Platinentest")

Time dependence (storage time, relaxation time of meas.)



Can we use rest-currents at this level as problem indicator?



# HV Test in Gas (7.5)



QC requirement: „Conditioning is performed ramping up and down HV several times. This procedure stops if after N trials a channel is not stable... After several hours must be stable with  $\leq 5\%$  of disconnected channels and with a current per channel below 50 nA.“

## Our observations:

- Ramping-speed is crucial.
- Rest-currents for strips & cathodes about 100 nA.
- Current fluctuations (limited by trip-limit 5 mA) stay for several days. Are they critical?
- Define stable running.



# Aachen Procedure HV Training in Gas



- **Flush with gas for ~8 h (6 vol.exchanges).**
- **Ramp-up in steps:**

HV wire	HV strip	HV cathode	$\Delta$ HV
2000	1000	-800	1000
2500	1200	-900	1300
3000	1400	-1000	1600
3400	1600	-1100	1800
3600	1800	-1200	1800
Over	Night	~8-10 h	
3700	1800	-1300	1800
3700	1800	-1400	1800
Over	Night	~8-10 h	

**Noticed: gas distribution inside SL very slow.**

**Total time: Good SL ~3 days**

**Incl.problem finding & repair (~1/3): .... 2-3 weeks**

**If problem, search for channel and disconnect (sometimes repair (glue, loose DC)). Very time consuming! Complicated by HV grouping.**

**No. of SL with HV problems in gas: 5/8 -> too high for MP**



# Results of HV Training in Gas



Netscape: File Edit View Go Communicator

Bookmarks Netsite: [http://www.physik.rwth-aachen.de/~hoepfner/Assembly/SL\\_Summary.html](http://www.physik.rwth-aachen.de/~hoepfner/Assembly/SL_Summary.html)

HV Training in ArCO<sub>2</sub>  
Highest HV Settings  
for longterm runs

SL #	Test in Air	Test in ArCO <sub>2</sub>
001	3600/1800/-1800	3600/1800/-1400
002	3600/1800/-1800	3595/1800/-1800
003	3600/1800/-1800	3600/1800/-1200
008	3700/3600/-3000	3500/1800/-1600
009	3600/1800/-1800	3600/1800/-1400
010	3800/3500/-2900	2100/1400/-1000
011	3700/1800/-1800	3700/1800/-1500
012	3700/1800/-1800	3700/1800/-1400 ?
013	3700/1800/-1800	3200/1400/-1000
014	3700/1800/-1800	3700/1800/-1500
015	3600/1800/-1800	3600/1800/-1600
016	3700/1800/-1800	2200/1200/-1000
019	3700/3600/3100	

02/04/2002 CA+OT+KH

**Question: What to do with close-to-limit cases (e.g. 3595 V for wires, 1200 for cathodes, 1780 for strips?)**

**Fraction of disconnected channels < 1%**  
Except SL 005 (10), SI 010 (4)

**Longterm stability: 2 SL have been operating for ~4 weeks. Occasionally current over threshold, subsequent ramp-up smoothly.**

Despite high voltage settings in air, problems in gas.



# Summary HV Remarks



- The HV training is **most critical/time consuming step** in the commissioning phase.
- 50% cells which got **cleaned in air, could not** hold the HV in gas.
- **Ramping speed** seems critical ( $< 10/5/5$  V/sec).
- What are typical **rest-currents** for strips and cathodes?
- Can we use rest-currents in air as a problem indicator? Could avoid opening of SL and time consuming repair after cable harness and connector installed.
- **We need an agreement what to do with close-to-limit cases.**
- It seems advisable to **ramp-up in air to higher voltages** to reduce problems in gas.
- Cathode voltages for test and operation.
- **What to store from tests:** on SL summary page (final settings, duration, number & cause of disconnected cells), Web accessible






# Front-end/Testpulse System




## QC requirement: Rates

### Tests done at Aachen:



- 1) Contact test, on average exchange 1 FEB per SL
- 2) Testpulses, check if all channel see testpulses of 2 V, threshold 15 mV
- 3) Cosmics data taking -> TH talk





1 SL completely tested: SL 015 cells 41 (FEB3-9), 47 (FEB3-15), 119 (FEB8-7), 135 (FEB9-7), 170 (FEB11-10) <50% expected hits



# TDC spectrum and Mean time



$$\text{Meantime} = \frac{1}{2} [dist(1) + dist(3)] + dist(2)$$







# A Typical Cosmics Output File (SL 15)



**Noise**  
~ 30 Hz

**Efficiency**  
~ 0.98

**Afterpulse probability**  
~ 0.08

**Meantime [mm]**  
~ 20

**RMS [mm]**  
~ 1.2...1.6

**Residual [mm]**  
~ 0.4

**RMS [mm]**  
~ 0.6...2

## 2.line: Meantime left/right with RMS

	0. +- 0.	0. +- 0.	0. +- 0.	0. +- 0.	0. +- 0.	0. +- 0.	0. +- 0.
1							
2	51.3 +- 3.4	0 +- 0	0.16 +- 0.02	20 +- 0.17	1.24 +- 0.12	0.784 +- 0.19	1.57 +- 0.13
2	0 +- 0	0 +- 0	20 +- 0.17	1.24 +- 0.12			
3	224 +- 7.2	1 +- 0	0.11 +- 0.016	20.2 +- 0.11	1.37 +- 0.08	0.348 +- 0.087	1.06 +- 0.062
3	20.3 +- 0.21	1.42 +- 0.15	20.1 +- 0.13	1.34 +- 0.095			
4	75.6 +- 4.2	1 +- 0	0.15 +- 0.019	20.1 +- 0.13	1.33 +- 0.094	0.205 +- 0.056	0.681 +- 0.04
4	20.3 +- 0.21	1.42 +- 0.15	20 +- 0.17	1.24 +- 0.12			
5	23 +- 2.3	0.986 +- 0.01	0.051 +- 0.011	20.4 +- 0.18	1.76 +- 0.12	0.142 +- 0.076	0.977 +- 0.054
5	20.5 +- 0.26	1.96 +- 0.18	20.2 +- 0.22	1.45 +- 0.15			
6	28.5 +- 2.6	1 +- 0	0.046 +- 0.011	20.5 +- 0.11	1.61 +- 0.079	0.204 +- 0.079	1.03 +- 0.056
6	20.4 +- 0.17	1.75 +- 0.12	20.5 +- 0.14	1.47 +- 0.1			
7	65.9 +- 3.9	0.995 +- 0.0054	0.044 +- 0.0097	20.3 +- 0.11	1.64 +- 0.079	0.42 +- 0.11	1.67 +- 0.081
7	20.3 +- 0.18	1.85 +- 0.13	20.4 +- 0.13	1.4 +- 0.095			
8	47.8 +- 3.3	0.968 +- 0.013	0.11 +- 0.015	20.3 +- 0.15	1.59 +- 0.11	0.147 +- 0.059	0.877 +- 0.041
8	19.9 +- 0.23	1.64 +- 0.17	20.7 +- 0.19	1.46 +- 0.13			
9	33.4 +- 2.8	0.991 +- 0.0064	0.11 +- 0.014	20.2 +- 0.12	1.33 +- 0.084	0.187 +- 0.081	1.31 +- 0.058
9	20.4 +- 0.16	1.37 +- 0.11	20 +- 0.17	1.2 +- 0.12			
10	35.7 +- 2.9	0.996 +- 0.0043	0.061 +- 0.011	20.2 +- 0.09	1.41 +- 0.064	0.423 +- 0.1	1.65 +- 0.072
10	20.2 +- 0.13	1.5 +- 0.095	20.3 +- 0.12	1.3 +- 0.084			
11	40.6 +- 3.1	0.996 +- 0.0037	0.043 +- 0.0085	20.4 +- 0.085	1.47 +- 0.06	0.413 +- 0.089	1.6 +- 0.063
11	20.4 +- 0.12	1.5 +- 0.086	20.5 +- 0.12	1.44 +- 0.084			
12	36.9 +- 2.9	0.989 +- 0.0064	0.063 +- 0.01	20.4 +- 0.12	1.48 +- 0.087	0.0745 +- 0.052	0.922 +- 0.037
12	20.4 +- 0.19	1.61 +- 0.13	20.4 +- 0.16	1.33 +- 0.11			
13	28.5 +- 2.6	0.979 +- 0.0077	0.053 +- 0.0091	20.6 +- 0.13	1.7 +- 0.09	0.26 +- 0.064	1.25 +- 0.045
13	20.6 +- 0.18	1.81 +- 0.13	20.5 +- 0.18	1.54 +- 0.13			
14	33.2 +- 2.8	0.994 +- 0.0043	0.08 +- 0.011	20.5 +- 0.083	1.59 +- 0.059	0.387 +- 0.078	1.54 +- 0.055
14	20.5 +- 0.13	1.73 +- 0.092	20.6 +- 0.11	1.44 +- 0.074			
15	52.2 +- 3.5	0.988 +- 0.0082	0.037 +- 0.0076	20.6 +- 0.11	1.6 +- 0.077	0.536 +- 0.13	2.01 +- 0.095
15	20.6 +- 0.18	1.81 +- 0.13	20.6 +- 0.13	1.36 +- 0.091			
16	36.9 +- 2.9	0.987 +- 0.0089	0.07 +- 0.0099	20.6 +- 0.13	1.36 +- 0.091	0.097 +- 0.052	0.769 +- 0.037
16	0 +- 0	0 +- 0	20.6 +- 0.13	1.36 +- 0.091			
17	26.6 +- 2.5	0.987 +- 0.0091	0.067 +- 0.01	20.3 +- 0.19	1.78 +- 0.13	0.238 +- 0.09	1.26 +- 0.064
17	20.3 +- 0.19	1.78 +- 0.13	0 +- 0	0 +- 0			



# Summary of SL Status



**SL SUMMARY**  
Results from gas tightness, HV and FE Tests

SL Number and SL type	Time constant Gas tightness HV + FE cover	Part of chamber No.	Status HV Test in gas	Total No. of dead channels	Cell No. Component	Dead FE-channel, Cell No.	SL Flyer (link to PS-file)
SL 001 - phi	140	1	OK	0		1	<a href="#">link to PS file</a>
SL 002 - theta	670	1	OK	0		0	
SL 003 - phi	260	1	OK	0		1	
SL 004 - phi		2	air				
SL 005 - theta	440	2	air	10	12, 22, 24, 18, 56, 178, 182, 204, 208 = Strips 144 Cathode		
SL 006 - phi		2	air	1	166 Strip		
SL 007 - phi	1200	exploded SL	OK	2	102 Strip 18 ???		
SL 008 - phi()	320		repair	1	... Wire		
SL 009 - theta			ongoing	1	141 Cathode left		
SL 010 - phi			repair				
SL 011 - phi()			OK	0			
SL 012 - theta			OK	1	210 Strip		
SL 013 - phi	6600		repair	3	66, 91, 76 Strips		
SL 014 - theta			ongoing	1	69 Strip		
SL 015 - phi()	230		OK	0		5	<a href="#">SL Flyer Cosmics</a>
SL 016 - phi			air				
SL 017 - theta			air				
SL 018 - phi()							
SL 019 - phi	500						
SL 020 - theta							
SL 021 - phi()							
SL 022 - phi							
SL 023 - theta							

## SL Summary Sheet

SL Summary Sheet:

SL#	015			
HV in ArCO <sub>2</sub> [V]	wires	strips	i-beams	date
	3600	1800	-1600	10.01.02
Training duration	~ 18 h			
Gas tightness	2600 min (2 HV cover)			
Dead cells	#	type		
Kanal 9	41	FE		
Kanal 15	47	FE		
Kanal 7	119	FE		
Kanal 7	135	FE		
Kanal 10	170	FE		

[SL Flyer Cosmics](#)

File from cosmics data taking



# Marinas Proposal from last CMS week



Index  
of /dbcms/db/MB3\_001/SL\_ph1\_002/L1\_ph1\_00002

Name	Last modified	Size	Description
<a href="#">Parent Directory</a>	20-Feb-02 16:11	-	
<a href="#">W FE.txt</a>	23-Jan-02 12:31	2k	
<a href="#">W FE L1 01jun15 1750...</a>	23-Jan-02 12:31	2k	
<a href="#">W FE L1 01jun15 1750...</a>	23-Jan-02 12:31	13k	
<a href="#">W FE L1 01jun15 1750...</a>	22-Jan-02 19:21	2k	
<a href="#">W FE L1 01jun15 1750...</a>	23-Jan-02 12:31	2k	
<a href="#">W HV.txt</a>	23-Jan-02 12:32	2k	
<a href="#">W HV L1 01jun15 1825...</a>	23-Jan-02 12:32	2k	
<a href="#">W HV L1 01jun15 1825...</a>	23-Jan-02 12:32	12k	
<a href="#">W HV L1 01jun15 1825...</a>	22-Jan-02 19:25	2k	
<a href="#">W HV L1 01jun15 1825...</a>	23-Jan-02 12:32	2k	

➔ Can local directories be linked ?

➔ Platform independent tools

➔ File format, units etc.



# Relevance of QC Information for future Data Analysis



Some data are **very relevant for muon reconstruction**, like corner block position needed for alignment. Other data, like wire tension, are **not essential** for data analysis but for **chamber operation**.

QC during production has different meaning (monitoring <-> correction). Divide QC data in 2 groups [app.no. of data per SL]:

## Values just noted but no correction

**1.strip position [4]**

**Gastightness [1]** ■

**No.of dead channels [0-10]** ■

**Corner block position [4]**

**O<sub>2</sub>-content [1]**

**Noise [200]** ■

**Efficiency [200]** ■

**Mean time [6 x 200]** ■

**Planarity [50]**

**HV settings [3]** ■

## QC until values are within limits

**Wire position [200]**

**Wire tension [200]**

**Rest-currents [25]**

■ Presently accessible  
via www



# QC Data Storage



**QC during production**

**Store QC data  
Controlling  
For public access  
For future reconstruction**

**DB  
HTML based  
Others**

**Use of information  
for muon  
reconstruction**

## Get started:

- Place priorities! Which data most urgently needed for public access (operation of chambers at ISR, alignment testbench, etc).

- Aim of data storage.

- Schedule.

I'd estimate ~4 weeks for this amount of data in Aachen.

Gastightness, O<sub>2</sub>-content  
HV settings  
No.of dead channels  
Corner block position  
1.strip position  
Noise  
Efficiency  
Mean time